Distributed by:

JAMECO® ELECTRONICS

www.Jameco.com ✦ 1-800-831-4242

The content and copyrights of the attached material are the property of its owner.

Overall Beldfoil® Shield

Audio, Control and Instrumentation Cables

Jameco Part Number 233146
(8719-060-100)

Description	Part No.	UL NEC/ C(UL) CEC Type	No. of Pairs	Color Code	Standard Lengths		Standard Unit Weight		Insulation Thickness		Jacket Thickness		Nominal OD		Nominal Capacitance			
					Ft.	m	Lbs.	kg	Inch	mm	Inch	mm	Inch	mm	* pF/ Ft.	* pF/ m	** pF/ Ft.	** pF/ m
16 AWG Stranded Conductors (19x29) • Tinned Copper • Twisted Pair • Overall 100% Beldfoil Shield • 18 AWG Stranded TC Drain Wire																		
Polyethylene Insulation • Chrome PVC Jacket																		
UL AWM Style 20253 (600V 80°C)	**8719**	NEC: CM, CL2	1	Black, Clear	U-500	U-152.4	24.5	11.1	.032	.81	.032	.81	.313	7.95	23	75	44	144
		CEC: CM			500	152.4	24.5	11.1										
					U-1000	U-304.8	47.0	21.4										
					1000	304.8	49.0	22.3										
					2000	609.6	100.0	45.5										
					5000	1524.0	245.0	111.4										
					10000	3048.0	430.0	195.5										
14 AWG Stranded Conductors (19x27) • Tinned Copper • Twisted Pair • Overall 100% Beldfoil Shield • 16 AWG Stranded TC Drain Wire																		
Polyethylene Insulation • Chrome PVC Jacket																		
UL AWM Style 20253 (600V 80°C)	**8720**	NEC: CM, CL2	1	Black, Clear	U-500	U-152.4	34.5	15.7	.032	.81	.035	.89	.355	9.02	24	79	47	154
		CEC: CM			500	152.4	34.0	15.5										
					1000	304.8	71.0	32.3										
					2000	609.6	138.0	62.7										
12 AWG Stranded Conductors (19x25) • Tinned Copper • Twisted Pair • Overall 100% Beldfoil Shield • 14 AWG Stranded TC Drain Wire																		
Polyethylene Insulation • Chrome PVC Jacket																		
UL AWM Style 20253 (600V 80°C)	**8718**	NEC CM, CL2	1	Black, Clear	U-500	U-152.4	48.5	22.0	.037	.94	.040	1.02	.400	10.16	25	82	49	161
		CEC: CM			500	152.4	51.0	23.2										
					1000	304.8	100.0	45.5										
					2000	609.6	198.0	90.0										







TC = Tinned Copper

*Capacitance between conductors.
**Capacitance between one conductor and other conductors connected to shield.